



10255 Philadelphia Court
 Rancho Cucamonga, Ca. 91730
 (909) 949-1600
 Fax (909) 949-1999

Official Load Test Report

Customer Power Gen			Cust. #		
Address 4698 Brookhollow Cir		Suite #		P.O. # 4434	
City Riverside		State Ca		Zip 92509	
Site Address			Invoice#		
			Phone		
			Fax		
Site Contact			Title LOAD TEST		
			Cell		

ENGINE		GENERATOR				ATS				
MFG.	John Deere	MFG.	Leroy Somer			MFG.				
MODEL	6068HF485T	MODEL	LSA 46.2M5			MODEL				
SERIAL	PE6068L123522	SERIAL	CG6M11234			SERIAL				
ARR.		KW	200	VOLTS	277 - 480	PF-8	VOLTS	120 - 240	PHASE	Single
HOURS		KVA		PHASE	Three	HZ-60	AMPS		POLES	

Time	09:15	09:30	09:31	09:45	09:46	10:00	10:15						
Load%	30	30	50	50	75	75	75						

VOLTS													
L 1-2	482.0	482.0	482.0	482.0	482.0	482.0	482.0						
L 2-3	482.0	482.0	483.0	483.0	483.0	483.0	483.0						
L 3-1	482.0	482.0	483.0	482.0	482.0	483.0	483.0						

AMPS													
L 1	71.3	71.3	120.3	120.4	180.7	180.8	180.8						
L 2	71.4	71.3	120.4	120.4	180.9	180.9	180.9						
L 3	71.4	71.4	120.7	120.8	181.2	181.3	181.2						

LOAD													
KW	60.0	60.0	100.0	100.0	150.0	150.0	150.0						
HZ	60.1	60.1	60.1	60.1	60.1								
P.F.	1.0	1.0	1.0	1.0	1.0	1.0	1.0						

Stator °F													
-----------	--	--	--	--	--	--	--	--	--	--	--	--	--

ENGINE													
Oil psi													
Water °F													
Fuel psi													
R.P.M.													

GENERATOR EXCITER													
Amps													
Volts													

Comments / Test Results

1hr load test
 15 minute 30%
 15 minute 50%
 30 minute 75%

Customer _____ Date 12/3/19

Technician W/O # L _____