

New Generator check-in Load Bank Form

NO LOAD – 15 Minutes @ rated speed

| He: 8657.7 | | | | | A-C Phase | | B-C Phase | | | C-A Phase | |
|-------------|------------|------|--------------|-------|--------------|------|--------------|------|-------|--------------|--|
| | Start time | Temp | Oil Pres. | Hertz | Volts | Amps | Volts | Amps | Volts | Amps | |
| Start | 9:23 | 54 | 41 | 60 | 480 | Q | 277 | 2000 | 277 | (4) | |
| After 15min | 9:38 | 153 | 40 | 60 | 480 | 0 | 247 | 0 | 277 | | |
| | | | | | TOTAL | | | | - | • | |

25% LOAD - 15 Minutes @ rated speed

| | | | | | A-C Phase | | B-C Phase | | C-A Phase | |
|-------------|---------------|------|--------------|-------|--------------|-------|--------------|-------|--------------|-------|
| | Start time | Temp | Oil Pres. | Hertz | Volts | Amps | Volts | Amps | Volts | Amps |
| After 15min | 10:30 | 176 | 49 | 40 | 480 | 125.6 | 481 | 125.2 | 480 | 126.2 |

50% LOAD - 15 Minutes @ rated speed

| | | | | | A-C Phase | | B-C Phase | | C-A Phase | |
|-------------|---------------|------|--------------|-------|--------------|-------|--------------|-------|--------------|-------|
| | Start time | Temp | Oil Pres. | Hertz | Volts | Amps | Volts | Amps | Volts | Amps |
| After 15min | 10:50 | 178 | 40 | VO | 480 | 249.5 | 480 | 249.1 | 480 | 251.1 |

100% LOAD – 4 Hours @ rated speed

| | | | | | A-C Phase | | B-C Phase | | C-A Phase | |
|----------|------------------------|-------------|--------------------|--------------|--------------|-------|--------------|------|--------------|------|
| 1st hour | Start time 1/:54 | Temp 180 | Oil Pres. 39 | Hertz (oO | Volts 480 | Amps | Volts 480 | Amps | Volts 480 | Amps |
| 2nd hour | 12:54 | 180 | 38 | 60 | 480 | 621.5 | 480 | (G) | 980 | 601 |
| 3rd hour | 1354 | 1181 | 38 | 60 | 480 | 630 | 480 | 620 | 480 | 160 |
| 4th hour | | | | | | | | | | |

NO LOAD – 5 Minutes @ rated speed

| | | | | | A-C Phase | | B-C Phase | | C-A Phase | |
|-------------|--------------|------|--------------|-------|--------------|------|--------------|------|--------------|------|
| | Stop time | Temp | Oil Pres. | Hertz | Volts | Amps | Volts | Amps | Volts | Amps |
| After 10min | 1015 | 178 | 40 | 60 | 980 | Ø | 277 | Ø | 277 | \$ |

| Labor Hrs : | Traval times | Miles | T-4-11-1 | |
|-------------|--------------|----------|------------------|--|
| Labor His . | Travel time: | Mileage: | Total labor Hrs: | |

| Verification of Preventive Maintenance : This Preventive applicable manu | Maintenance Inspection and follow up repairs were complete ufacturer procedures, guidelines, and specifications. | d in accordance with |
|--|--|----------------------|
| Nichole Menting | / hull h | 4/14/21 |
| Verified By – Name (print) | Verified By – Signature | Date |