

Load Bank Test Form



Date: 31-Jan-2022

TECNICIAN Nick Coots

Customer:

Work Order Number:

Engine: Detroit Diesel

Location: MAE Shop

Model: 6043TKG5

Start Time: 2:40 PM

S/N: 04R0033456

End Time: 3:40 PM

Genset Model: 135GS

S/N: 686938

Hours	Volts	Amps L1	Amps L2	Amps L3	Frequency	kW Load	Water Temperature	Oil PSI	Ambient Temp	Recovery
14:40	482	171	172	171	60.1	99%	180	70	61	
14:55	483	170	173	171	60	99%	184	68	61	
15:10	482	171	172	171	59.9	99%	188	65	61	
15:25	483	170	171	171	60.1	99%	188	65	61	
15:40	483	170	171	171	60.1	99%	188	65	61	