



PC	PART #	QTY	DESCRIPTION
MATERIAL:	WTIF017700	1	3 PH. ELEC. TEMP. MONITOR
MATERIAL:	TCWF000500	40	THERMOCOUPLE WIRE
MATERIAL:	LUGF006500	1	RING TONGUE LUGS
MATERIAL:	CBLF009800	1	#12 AWG SIS WIRE
MATERIAL:	TBKF000100	1	8 POLE TERMINAL BLOCK
MATERIAL:	FSEF000700	2	FUSES (15 AMP)
MATERIAL:	FSHF000200	2	FUSE HOLDER
MATERIAL:	LUGF006300	1	WIRE SPLICE
MATERIAL:	WRMF000500	1	SLEEVE TYPE WIRE MARKERS
MATERIAL:	CBLF004500	1	#12 AWG SIS WIRE
MATERIAL:	LUGF006200	1	RING TONGUE LUGS
MATERIAL:	CBLF002200	1	#12 AWG SIS WIRE GREEN
FANS			
MATERIAL:	MTRF024101	12	FAN MOTOR 240V, .731A
MATERIAL:	BLDF001700	12	FAN BLADE
MATERIAL:	TBKF000400	6	2 POLE TERMINAL BLOCK
MATERIAL:	CBLF009800	1	#12 AWG WIRE
MATERIAL:	WRMF000500	1	WIRE MARKERS
MATERIAL:	LUGF001200	1	RING TONGUE LUGS
MATERIAL:	LUGF006300	1	WIRE SPLICE

- NOTES:
- THREE PHASE ELECTRONIC TEMP. MONITOR (E.T.M.) CONTACT POSITIONS SHOWN ARE WITH THE E.T.M. DE-ENERGIZED.
 - AN INTERNAL BUZZER SOUNDS EACH TIME THE "ALARM" BECOMES ACTIVE. THE BUZZER CAN BE SILENCED BY PRESSING THE "SILENCE" PUSH-BUTTON. THE BUZZER WILL THEN TURN OFF AND REMAIN OFF UNTIL A NEW ALARM OCCURS.
 - DE-ENERGIZE TRANSFORMER & FAN CIRCUIT BEFORE PERFORMING MAINTENANCE.
 - CONTACTS ARE ACTIVATED AT THE FOLLOWING SWITCH SETTINGS:
 - FRONT PANEL DISPLAY REFLECTS HOTTEST PHASE.

RISE	FAN CKT.	ALARM CKT.	TRIP CKT.
80°C	120°C	200°C	210°C
115°C	155°C	200°C	210°C
150°C	190°C	200°C	210°C

FAN CONTACT RATINGS:			
FORM A CONTACTS	RESISTIVE	HORSEPOWER	CONTACT BAND SETTING
120 or 240 VAC	30 AMPS	1 or 2 HP	10°C
ALARM CONTACT RATINGS:			
FORM C CONTACTS	RESISTIVE	HORSEPOWER	CONTACT BAND SETTING
120 or 240 VAC	10 or 8 AMPS	- - - -	5°C
TRIP CONTACT RATINGS:			
FORM C CONTACTS	RESISTIVE	HORSEPOWER	CONTACT BAND SETTING
120 or 240 VAC	10 or 8 AMPS	- - - -	5°C

01 REVISION	THE INFORMATION ON THIS DOCUMENT WAS CREATED BY CUTLER-HAMMER. IT WAS DISCLOSED IN CONFIDENCE AND IS ONLY TO BE USED FOR THE PURPOSE IN WHICH IT WAS SUPPLIED.		DFTR PROG	DATE 9/17/2012		TITLE	WAYNE CO. CONSOLIDATED JA 002,005
	FEDERAL ID NO. 88725	PRODUCT CODE OL	REVISION 01	G.O. MDT0006091		DWG 11660CP1	SHEET 1 OF 01
	CUTLER-HAMMER		TYPE TRANSFORMER	WIRING		COEFTDL REV 02	