



GenSolutions LLC

11729 Spriggs Way
Houston Texas, 77024
936-443-4378

LOAD TEST REPORT

Account Name:

Power Gen Enterprises

Equipment Location: (Physical Address)

In shop

Engine

CAT 3412
812065741

Generator

Work Order Number:

PASS/FAIL

Engine Fluids:

Engine Fluids:
Oil Level
Coolant Level
Bee. Fuel Level
End Fuel Level

Full
Full
-
-

Service Technician

P. Belin

Test Date

1/18/2022

Customer Witness

Make:
Model:
Serial Number:

Test Equipment
Avtron
1250kw

Line	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
	1:00	398	481	60	150	181	181	181	78	160°	55
	1:15	398	480	60	150	181	180	181	72	178°	55
	1:15	398	480	60	306	361	361	361	72	175°	55
	1:30	399	480	60	306	361	361	361	70	181°	55
	1:45	399	480	60	300	361	361	360	70	181°	55
	1:45	399	480	60	450	542	540	543	70	181°	55
	2:00	399	480	60	450	542	541	543	68	182°	55
	2:15	400	480	60	450	542	541	542	68	182°	55
	2:30	400	480	60	450	542	540	542	68	182°	55
	2:45	400	480	60	590	710	704	713	68	182°	55
	3:00	400	480	60	590	711	707	712	68	184°	55
	3:05	401	480	60	6	6	6	6	70	179°	55