CUSTOMER:	DATE OF	SERVICE:	SERVICE	ORDER #:	CUSTON	CUSTOMER PO#			TYPE	CONTACT NAME:		
POWER GENERATION	10/11/22						PM1					
POWER GENERATION	10/11/	11/22						PIVII		VICTOR SEROPIAN		
MAKE:	MODEL:			SERIAL NU	MBER:		UNIT ID N	IUMBER:		START HOURS-END HOURS		
MQ	DCA2	20SSJI	U4F	801091	6							
ENGINE MAKE	ENGINE N	MODEL		ENGINE FAMILY			ENGINE S	PFC-CPI		ENGINE FUEL TYPE		
JD				Ending IV willer			PE6068U044175			DIESEL		
JD	6068HI	FG09						0044175)	DIESEL		
ATS 1 MODEL	ATS 1 SEF	ATS 1 SERIAL NUMBER			ATS 2 MODEL			IAL NUMBER		TYPE OF CRITICAL EQUIP:		
										PORTABLE		
SERVICE CHECK ITEMS	GENERATOR SPECS							SYSTEMS				
			0110120									
CHECK OIL LEVEL	PASS	KW-KVA-	AMPERAG	E	220KVA-265A		B1 STATIC/CRANK VOLTS					
CHECK COOLANT LEVEL	FULL	VOLTAGE	CODE-PF		277/480		B1 DATE					
CHECK GEAR BOX OIL	N/A	GEN RUN	INING CHEC	CKS				C/CRANK VOL	.TS			
CHECK GOVERNOR OIL	N/A	OIL PRES	SURE		85		B2 DATE CODE					
CHECK ALL HOSES	PASS		1P UNLOAD		168		B1/B2 W/	ATER LEVEL	SIZE	PASS		
CHECK ALL HOSECLAMPS	PASS	WTR TEMP LOADED			192		CHARGER AMPS			N/A		
INSPECT FOR LEAKS	PASS	FREQUEN	ICY UNLOA	DED	60.1		TRANSFER SWITCH ITEMS					
TURBO LEAKS END PLAY	PASS	,	ICY LOADE	D	60.0		CONTACT	TEMP UTL-LI	D-GEN	N/A		
INSPECT FAN HUB-DRIVE	PASS VOLTS UNLOADED				480		UTILITY VOLTAGE			N/A		
INSPECT BELTS	PASS				479		GEN VOLTAGE			N/A		
INSPECT RADIATOR & CAP	PASS	AC AMPS	LOADED		215A		SET-CHECK EXERCISER			SATURDAY		
CHECK RADIATOR EXH	PASS	PF UNDE			8.0		INSPECT I			PASS		
CHECK FREAH AIR INTAKE	PASS	DC ALT V			14.0			START-TRANS	FER	N/		
CHECK DAY TANK	N/A		MPERAGE		4.2			O UTL TIME		N/A		
INSPECT GOV CONTROLS	PASS	RPM UNI	.OADED		1801		COOLDO	NN TIME		N/A		
INSPECT EXCITER	PASS				1799			ETY ITEMS				
CHECK EXCITER BEARING	PASS			NT	PASS			NK/OVERSPE	ED	N/A		
LUBE ALL POINTS	PASS	COOLANT SCA/DCA			PASS		LOW OIL PRESSURE			N/A		
INSPECT MLCB WIRING	PASS	FUEL STATIC						LOW COOLANT LEVEL		N/A		
INSPECT CONTROL GAUGES	PASS	FUEL CRANK			N/A		HI WATER TEMPERATURE			N/A		
INSPECT FOR DAMAGE	PASS	FUEL RUN			N/A		E-STOP/REMOTE E-STOP)P	N/A		
INSPECT BATTERY CHARGER	PASS	FUEL LEVEL IN TANK			100%		RUPTUR			N/A		
CLEAN UNIT OF DEBRIS	PASS	DPF PRESSURE IDLE			N/A		LOW FUEL LEVEL SD			N/A		
CHECK CLEAN AIR FILTER	PASS DPF PRESSURE LOAI			N/A		GASEOUS FUELED ENGINES			NVA			
CHECK CCV FILTER	N/A DPF TEMP UNLOAD		ED	N/A		CHECK PLUGS AND WIRES			N/A			
CHECK OIL RESERVE SYSTEM	N/A				N/A			STRIB CAP/RT	ΓŘ	N/A		
INSPECT REMOTE FUEL SYS	N/A							V VALVE		N/A		
ADDITIONAL DEDAIDS:	PASS	CHECK EC	U VALUES		N/A		INSPECT I	REGULATOR/	AFRC	N/A		

ADDITIONAL REPAIRS:

QTY	PART NUMBER	DESC	RIPTION	QTY	PART NUMBER	DESCRIPTION				
UNIT IN	AUTO/MLCB CLOSED		TECHNICIAN SIGNATURE:		DATE: 7/27/22					

UNIT IN AUTO/MLCB CLOSED	TECHNICIAN SIGNATURE: KUREY, ADAM	DATE: 7/27/22
N/A	KUREY, ADAM	
CUSTOMER REFUSES TRANSFER TEST	CUSTOMER SIGNATURE:	DATE:
N/A		

Load Bank Report

Work Order # Service Type													Site Address	RIVERSIDE YARD					Latitude				
PM Load Bank												Addiess				Longitude							
Site Number Site Name										Name (Pr		Technician Signiture ADAM KUREY								artup/PM			
Engine Make/Model Engine Serial Number						Generator Make				Generator Model #					Fuel Type			10/11/2	kW Rating Hour Meter				
JD						MQ							(Diesel			200	5,978.40	5			
Transfer Switch #1 Make Transfer Switch #1 Model # Transfer Switch #1 S/N					Transfer Switch #2 Make			Transfer S	Switch #2 M	ode l #	Transfer Switch #2 S/I	N	Amps Voltage			# Phases		Hz					
																277/48)	3 Phas	se	60 Hz			
Transfer Switch #3 Make Transfer Switch #3 M			iodel # Transfer Switch #3 S/N			Transfer Switch #4 Make		Transfer S	Switch #4 M	odel #	Transfer Switch #4 S/I	N	Transfer Switch #5 M	ake	Transfer S	witch #5 M	odel#	Transfer Switch #5 S/N					
								For site	tes with more than 5 transfer switches please add additional transfer switch information to Foot Notes														
Time	Hour Meter	Loaded %	кw		Voltage			Amperage	,	Oil PSI	Coolant Temp.	Amb Air Temp.											
	□ 1	Three Phas	е	A-B	В-С	C-A	Phase A	Phase B	Phase C														
	s	Single Phas	e	A-N	B-N	А-В	Phase A	Phase B	N/A														
Start	1:15P	100%	180	480	479	480	215	211	213	78	173	73											
0:15	1:30P	100%	180	479	479	479	215	212	213	70	189	73											
0:30	1:45P	100%	180	479	479	479	215	211	212	59	200	73											
0:45	2:00P	100%	180	479	479	479	215	212	213	51	201	74											
1:00	2:15P	100%	180	479	479	479	215	212	212	48	201	74											
1:15		0%																					
1:30		0%																					
1:45		0%																					
2:00		0%																					
2:15		0%																					
2:30		0%																					
2:45		0%																					
3:00		0%																					
3:15		0%																					
3:30		0%																					
3:45		0%																					_
4:00		0%																					
4:15		0%																					
Cool Down		0%																					
													Footnotes										
													Comments	5									