

### Official Load Test Report

Customer <u>PowerGen Services</u>			Cust. #		
Address		Suite #		P.O. #	
City		State		Zip	
Site Address <u>4698 Brookhollow Circle</u>			Phone		
<u>Riverside CA.</u>			Fax		
Site Contact			Title		
Cell					

ENGINE		GENERATOR				ATS	
MFG.	Cummins	MFG.	MQ Power		MFG.		
MODEL	QSB7-G7	MODEL	DF1651C		MODEL		
SERIAL	73404440	SERIAL			SERIAL		
ARR.		KW	120	VOLTS	277 - 4 <input type="checkbox"/>	PF-8	
HOURS	13129.6- 13130.6	KVA		PHASE	Three <input type="checkbox"/>	HZ-60	
				AMPS		POLES	

Time	11:45	12:00	12:01	12:15	12:16	12:30	12:31	12:45				
Load%	25	25	50	50	75	75	100	100				

VOLTS												
L 1-2	480	480	480	480	480	480	480	480				
L 2-3	482	482	482	482	482	482	482	482				
L 3-1	482	482	482	482	482	482	482	482				

AMPS												
L 1	38	38	75	75	105	105	147	147				
L 2	38	38	76	76	106	106	148	148				
L 3	38	38	75	75	106	105	147	147				

LOAD												
KW	30	30	60	60	90	90	120	120				
HZ	60	60	60	60	60	60	60	60				
PF	1	1	1	1	1	1	1	1				

Stator °F												
ENGINE												
Oil psi	60	60	60	61	60	60	59	59				
Water °F	175	175	180	188	188	188	190	189				
Fuel psi												
R.P.M	1801	1801	1800	1800	1800	1800	1799	1799				

GENERATOR EXCITER												
Amps												
Volts												

Comments / Test Results