

3208 GEN SET ENGINE

Engine Serial Number - 30A (Build Date - 12/1991, Test Date - 12/1991, Ship Date - 01/1992)

▼ ENGINE - ENTIRE GROUP (30A)

Qty.	NPR	Note	Part No.	Change Level	Req. Qty	Part Name
		I	PA2346	06	001	3208 DIT PACKAGE GEN SET
	NPR	IY	7W-8603	07	001	ENGINE AR
	NPR	IY	1W-6465	01	001	SUPPORT GP-ENGINE
	NPR	IY	1W-6714	00	001	LIFTING GP-ENGINE
	NPR	IY	2W-0622	00	001	BASE GP-ENGINE & GENERATOR
		I	2W-0973	04	001	INSTRUCTIONS-INSTALLATION
	NPR	IY	2W-1455	00	001	ELBOW GP-EXHAUST
	NPR	IY	4N-9312	05	001	STARTING MOTOR GP-ELECTRIC
	NPR	IY	4W-1142	01	001	SEPARATOR GP-WATER
	NPR	IY	4W-1143	03	001	LINES GP-FUEL
	NPR	IY	4W-8971	03	001	GENERATOR AR
		I	5N-7529		001	NOTE - ASSEMBLY INSTRUCTIONS
		I	5N-7562	00	001	CHART
	NPR	IY	5N-9079	02	001	INSTALLATION AR-GENERATOR
	NPR	IY	5N-9237	02	001	LINES GP-FLEXIBLE FUEL
		I	5P-2506	00	001	LITERATURE GP
	NPR	IY	7W-0919	01	001	MOUNTING GP-CONTROL PANEL
	NPR	IY	7W-5127	01	001	FAN GP-BLOWER
	NPR	IY	7W-5128	03	001	RADIATOR GP
	NPR	IY	8N-4670	04	001	AIR CLEANER GP
	NPR	IY	4W-0888	02	001	SHUTOFF GP-ELECTRICAL
		I	5N-7574		001	NOTE-CTL&PWR.PANL CHART 7C1000
	NPR	IY	7C-5023	02	001	MOUNTING GP-CONTACTOR
	NPR	IY	7C-6513	06	001	CONTROL GP-EMCP ELECTRONIC
	NPR	IY	7C-9285	00	001	WIRING GP-ENGINE
		I	3L-0348		001	PACKAGE GS TEST - EMCP
	NPR	I	7C-4858	03	001	CONNECTION GP-ELECTRICAL
	NPR	I	4P-5963	00	001	SENSOR GP-SPEED
		I	PA3815	00	001	GOV GP-WWD 8290 W/1724 ACTUAT.

PART NUMBERS

	NPR	IY	7C-9184	01	001	MOUNTING GP-ACTUATOR
	NPR	I	7E-0597	00	001	CONTROL AS-GOVERNOR
	NPR	I	7E-0598	00	001	ACTUATOR AS-GOVERNOR
	NPR	I	7E-2583	00	001	CONTROL AS-GOVERNOR
		I	PA2360	00	001	ALTERNATOR GP - 24 V
	NPR	IY	7C-5024	00	001	MOUNTING GP-CIRCUIT BREAKER
	NPR	IY	7W-3862	00	001	ALTERNATOR GP-CHARGING
	NPR	IY	7C-9005	00	001	HEATER GP-JACKET WATER
		I	0P-9812		001	E_____V_5 EMCP PANEL
		I	0P-9715		004	EXTRA LITERATURE - ENGLISH
		I	0P-9871		001	PRE 01JAN92 PRC PRO PGM515-1
		I	PP1493	01	001	241 BHP 164 GEN KW WOF 60 HZ P
		I	0T-9512	00	001	180 KW @ 1800 RPM (241 BHP)
	NPR	I	4N-6119	01	001	SPRING
		I	5N-7545		001	NOTE-REMOVE STD GOV SPRING.
		I	0P-9286		001	DUAL VOLTAGE CAPABILITY

Key:

I Installed

Y Separate Illustration